



2035T161M3 4059849  
2035T162M3 4059850  
2035T163M3 4059851

**Disconnect from mains supply before replacing the fuse or the lamp.**  
Vor dem Einsetzen der Sicherung oder der Lampe Spannungsfreiheit herstellen.  
**Débrancher le secteur avant de remplacer le fusible ou l'ampoule.**  
Desconectar del suministro de la red, antes de realizar la sustitución del fusible o de la lámpara.  
**Voor het vervangen van lamp of zekering, eerst netspanning uitschakelen.**  
Koppla bort spänningen före byte av en säkring eller en lampa.



**Switch Off**  
Abschalten  
**Débrancher**  
Desconectar  
**Uitschakelen**  
Stäng av



**WARNING:**

1. LUMINAIRE MUST BE EARTHED
2. DO NOT INSULATION TEST

**NOTE:**

1. THIS UNIT SHOULD BE CLEANED BY USING WARM SOAPY WATER AND A SOFT CLOTH - ENSURE UNIT IS SWITCHED OFF DURING CLEANING
2. DISPOSE OF LAMPS IN ACCORDANCE WITH LAMP MANUFACTURER'S INSTRUCTIONS

This luminaire designed for maintained emergency operation with a duration of 3 hours, is suitable for interior ceiling or wall mounting to a 50.8mm conduit box or directly to a flat mounting surface and can be semi-recessed using Recessing Kit 4037857 (2045ORK).

Installation should be carried out by a suitably qualified person in accordance with good electrical practice and the appropriate national wiring regulations.

Switch off mains electrical supply before commencing installation.

**INSTALLATION PROCEDURE**

Remove diffuser (E) as shown.

Check rating marked on label (A) conforms with mains electrical supply.

Partially screw suitable M4 screws in conduit box or prepare suitable fixings in mounting surface at 120mm centres for outrigger fixing holes.

Enter connection date on battery pack label (D).

Fit supplied grommets (K) in

housing, and pass mains leads and unswitched lead through.

Secure housing (C) to conduit box or to mounting surface using suitable screws. **NOTE:** Housing (C) is marked TOP if wall mounting.

Cover supply leads with supplied silicone sleeving, connect mains supply leads in terminal block (H) and unswitched live in 1A fused terminal block (G).

Fit appropriate lamp as indicated on label (A).

Connect black lead from battery pack to TERMINAL 3 in module (J).

**TESTING**


Switch on mains supply and check that charge indicator lamp (F) is on.

Leave luminaire on continuous charge for 24 hours.


Simulate mains failure, and check that lamp (F) operates for 3 hours. If full duration of 3 hours is not achieved, repeat charge/discharge cycle as battery packs may have discharged in stock and will require conditioning.



**REMOVING DIFFUSER**  
1. PRESS DOWN 2. PUSH TO SIDE 3. LEVER OUT



**FITTING DIFFUSER**  
1. FLEX IN 2. INSERT UNDER RIM 3. CENTRALISE



**Replace any cracked protective shield.**

Dieses symbol bedeutet, dass defekte Schutzgläser sofort ersetzt werden müssen.

**Ce symbol indique que vous devez remplacer tout verre de protection fêlé.**

Este símbolo indica que hay que reemplazar filtros en caso de rotura o desperfectos.

**Dette symbolet indikerer at alle ødelagte (sprukne) sikkerhetglass må skiftes.**

Valaisinta ei saa käyttää ilman suojalasia vioitunut suojalasi on vaihdettava uuteen ennen valaisimen käyttöön ottoa.

**Suitable for use indoors**  
Geeignet für Innenanwendung  
**Pour un usage interne**  
Adecuada para uso en interiores  
**Geschikt voor gebruik binnen**  
Lämpligt för inomhusbruk



This Electrical Product  
MUST be recycled.



< Millimetres >