



**Disconnect from mains supply before replacing the fuse or the lamp.**  
 Vor dem Einsetzen der Sicherung oder der Lampe Spannungsfreiheit herstellen.  
**Débrancher le secteur avant de remplacer le fusible ou l'ampoule.**  
 Desconectar del suministro de la red, antes de realizar la sustitución del fusible o de la lámpara.  
**Voor het vervangen van lamp of zekering, eerst netspanning uitschakelen.**  
 Koppla bort spänningen före byte av en säkring eller en lampa.



**Switch Off**  
 Abschalten  
**Débrancher**  
 Desconectar  
**Uitschakelen**  
 Stäng av







2 X 13W				2 X 18W					
	+	-		+	-				
A	2525142	2525157	2516998	2517007	A	2525162	2525177	2517009	2517018
B	2525144	2525159	2517000	2517008	B	2525164	2525179	2517011	2517019








**Suitable for use indoors**  
 Geeignet für Innenanwendung  
**Pour un usage interne**  
 Adecuada para uso en interiores  
**Geschikt voor gebruik binnen**  
 Lämpig för inomhusbruk

	2 x 13W	2 x 18W
Dim 'A'	290	300
Dim 'B'	190	200
Dim 'C'	50	50

\*IP23/IP44  
 Accessory Ring Only - see IS529





**Routine Testing**

Testing should be carried out in accordance with the recommendations of BS 5266.

- 1.) A monthly functional test.
  - 2.) Twice yearly, a one hour duration test.
  - 3.) Every three years, a full three hour duration test.
- (The above tests assume a three hour system)
- 4.) Batteries shall be replaced when the luminaire no longer meets 3 hours duration performance.
  - 5.) Testing could be performed by interrupting the fixed phase supply for the test duration, during which the luminaire should remain lit.

To assist with this testing, a test record chart is supplied below. The test engineer should sign and date each test. If the charge indicator (LED) is unlit, this signifies a fault. To increase the chance of a fault being reported between monthly tests, it is advisable that the occupants are made aware of the purpose of the indicator.


This module should not be modified or repaired by any person other than those nominated by the manufacturer. Any unauthorised modifications may render the module unsafe and will invalidate our warranty and conformance to any safety standards that may apply. The company will accept no responsibility for any modified modules, or for damage caused as a result of any modifications.

All details are given for guidance only and do not constitute a contract. We reserve the right to change the characteristics of products without notice.

**TEST RECORD** Type..... Location.....

Month	Test	1st. Year	2nd. Year	3rd. Year	4th. Year	5th. Year	6th. Year
	1. Functional						
	2. Functional						
	3. 1. Hour						
	4. Functional						
	5. Functional						
	6. Functional						
	7. Functional						
	8. Functional						
	9. 1. Hour						
	3. Hour						
	10. Functional						
	11. Functional						
	12. Functional						

Suitable for use indoors  
 Geeignet für Innenanwendung  
 Pour un usage interne  
 Adecuada para uso en interiores  
 Geschikt voor gebruik binnen  
 Lämpig för inomhusbruk



< Millimetres >

**Concord:marlin**

Avis Way Newhaven East Sussex BN9 0ED  
 T 0870 606 2030 F 01273 512 688 email: information@concordmarlin.com

