



Disconnect from mains supply before replacing the fuse or the lamp.
Vor dem Einsetzen der Sicherung oder der Lampe Spannungsfreiheit herstellen.
Débrancher le secteur avant de remplacer le fusible ou l'ampoule.
Desconectar del suministro de la red, antes de realizar la sustitución del fusible o de la lámpara.
Voor het vervangen van lamp of zekering, eerst netspanning uitschakelen.
Koppla bort spänningen före byte av en säkring eller en lampa.




Switch Off
Abschalten
Débrancher
Desconectar
Uitschakelen
Stäng av



REMOVING DIFFUSER
1 PRESS DOWN 2 PUSH TO SIDE 3 PULL OUT

FITTING DIFFUSER
1 FLEX IN 2 INSERT UNDER RIM 3 SLIDE BACK



NOTE: THIS LUMINAIRE SHOULD BE CLEANED BY USING WARM SOAPY WATER AND A SOFT CLOTH. ENSURE LUMINAIRE IS TURNED OFF DURING CLEANING

DISPOSE OF LAMPS IN ACCORDANCE WITH LAMP MANUFACTURER'S INSTRUCTIONS

This luminaire, designed for maintained emergency operation with a duration of 3 hours, is suitable for interior wall or ceiling mounting to a 50.8mm conduit box and or directly to mounting surface.

Installation should be carried out by a suitably qualified person in accordance with good electrical practice and the appropriate national wiring regulations.

Switch off mains electrical supply before commencing installation.

INSTALLATION PROCEDURE

Carefully remove diffuser (L) as shown.

Check rating marked on label (D) conforms with mains electrical supply.

Screw suitable M4 screws in conduit box or alternatively prepare suitable fixings in mounting surface at 190mm centres for outrigger fixing holes (K). NOTE: Gallery is marked TOP for wall mounted applications.

Enter supply connection date on battery pack label (F).

Fit supplied grommets (E) in gallery, and pass mains supply leads and unswitched live mains supply lead through grommets.

Secure gallery (G) to conduit box or to mounting surface using suitable fixing screws through outrigger holes (K).

Cover mains supply leads with supplied sleeving and connect leads in respective terminals in terminal block (C).

Cover unswitched live mains supply lead with supplied sleeving and connect lead in terminal block (C) which is protected by a 3A fuse.

Fit appropriate lamp as indicated on label (D) in lampholder.

Connect battery socket (B) to plug (A).

Fit diffuser (L) into gallery as shown, ensuring it is held concentrically by retaining clips (H).

TESTING

Switch on mains supply and check that charge indicator lamp (J) is on. Leave luminaire on continuous charge for 24 hours.

Simulate mains failure, and check that lamp operates for 3 hours. If full duration of 3 hours is not achieved, repeat charge/discharge cycle as battery packs may have discharged in stock and will require conditioning.

WARNING: THIS LUMINAIRE MUST BE EARTHED

WARNING: DO NOT INSULATION TEST



Replace any cracked protective shield.

Dieses symbol bedeutet, dass defekte Schutzgläser sofort ersetzt werden müssen.

Ce symbol indique que vous devez remplacer tout verre de protection fêlé.

Este simbolo indica que hay que reemplazar filtros en caso de rotura o desperfectos.

Dette symbolet indikerer at alle ødelagte (sprukne) sikkerhetglass må skiftes.

Valaisinta ei saa käyttää ilman suojalasia vioitunut suojalasi on vaihdettava uuteen ennen valaisimen käyttöön ottoa.

Suitable for use indoors

Geeignet für Innenanwendung

Pour un usage interne

Adecuada para uso en interiores

Geschikt voor gebruik binnen

Lämplig för inomhusbruk



This Electrical Product
MUST be recycled.



06.06

< Millimetres >

Concord:marlin

Avis Way Newhaven East Sussex BN9 0ED
T 0870 606 2030 F 01273 512 688 email: information@concordmarlin.com



© Concord Lighting Ltd.