


Emergency Optix 1-10V Dimmable

Installation Instructions  This Product MUST be EARTHED

IS5782B

4063959
4063961
4063963
4064007
4064009
4064011


Disconnect from mains supply before replacing the fuse or the lamp.
Vor dem Einsetzen der Sicherung oder der Lampe Spannungsfreiheit herstellen.
Débrancher le secteur avant de remplacer le fusible ou l'ampoule.
Desconectar del suministro de la red, antes de realizar la sustitución del fusible o de la lámpara.
Voor het vervangen van lamp of zekering, eerst netspanning uitschakelen.
Koppla bort spänningen före byte av en säkring eller en lampå.



Switch Off
Abschalten
Débrancher
Desconectar
Uitschakelen
Stäng av

IMPORTANT NOTES

1. Install in still air voids only.
2. Use supplied polythene glove when handling the reflector.
3. Any external cable or wiring must not come into contact with gear unit unless resistant up to 85°.



Installation Procedure

Refer to table for aperture and recess dimensions.

Prepare aperture in mounting surface.

Remove reflector (K) and check voltage rating marked on label (D) conforms with mains electrical supply.

Remove end panel (H).

Remove mounting clips (M) from reflector housing (L) as shown in Fig. 1.

Connect mains supply leads in terminal block (E) and cable leads from receiver (J) in terminal blocks (F) and (G) as shown in wiring diagram on leaflet supplied with RF Receiver.

Fit end panel (H) ensuring all cables are securely clamped.

Connect battery plug (A) and enter date on battery label (C).



Place remote box through aperture.

Refer to table and secure housing (L) in ceiling aperture with mounting clips (M) as shown in Fig. 2.

Fit reflector (K) in housing (L), ensuring that rubber washer is positioned on end of screw as shown in Fig. 3.


Fit appropriate lamps as indicated on label (D).

NOTE: Unit is protected by F2A fuse (B).



Ceiling Thickness (mm)	Fixing Slot
5 - 16	Bottom
16 - 31	Top

To avoid flexing of sheet metal tiles use a 6mm backing board



	A	B	C
1 x 13/18W	175	240	200
1 x 26/32W 2 x 13/18W	200	250	200
1 x 42W 2 x 26/32W	225	260	200

Routine Maintenance

Routine maintenance must be carried out in compliance with the requirements of BS5266:Part 1 - Emergency Lighting of Premises.

The following tests assume a three-hour system.

- Daily:**
1. Check that any recorded faults have been rectified.
 2. Check that the maintained emergency lamp is operative.
 3. Check that the charge indicator light is illuminated.
- Monthly: (Functional)**
1. Simulate a mains failure and check that the emergency lamp illuminates and remains on for several minutes.
 2. After reverting back to mains supply check the charge indicator light is illuminated.
- Six Monthly: (1 Hour)**
1. Simulate a mains failure and check that the emergency lamp illuminates and remains on for one hour.
 2. After reverting back to mains supply check the charge indicator light is illuminated.
 3. On restoring the mains supply the unit will require approximately 24 hours to recharge before becoming fully operational.
- Three Years: (3 Hours)**
1. Simulate a mains failure and check that the emergency lamp illuminates and remains on for at least 3 hours.
 2. After reverting back to mains supply check the charge indicator light is illuminated.
 3. On restoring the mains supply the unit will require approximately 24 hours to recharge before becoming fully operational.

It is recommended that the battery packs and lamps are replaced every 4 years or sooner if the units performance fails to meet the above requirements. To maintain optimum unit performance, only approved replacement battery packs and lamps must be used.

All routine maintenance checks must be recorded on the unit Routine Test Record and must be made available for inspection at all times.

Installation and Commissioning Record

Luminaire Model Ref: _____ Location: _____

Installed By: _____ Date: _____

Commissioned by: _____ Date: _____
(Full Charge and Discharge Cycle)

Routine Test Record

Monthly Test	First Year		Second Year		Third Year		Forth Year		Fifth Year	
	Signed	Dated	Signed	Dated	Signed	Dated	Signed	Dated	Signed	Dated
Functional										
Functional										
Functional										
Functional										
Functional										
1 Hour Duration										
Functional										
Functional										
Functional										
Functional										
Functional										
1 Hour Duration										
3 Hour Duration										

Suitable for use indoors
 Geeignet für Innenanwendung
Pour un usage interne
 Adecuada para uso en interiores
Geschikt voor gebruik binnen
 Lämpig för inomhusbruk



Replace any cracked protective shield.
 Dieses symbol bedeutet, dass defekte Schutzgläser sofort ersetzt werden müssen.
Ce symbol indique que vous devez remplacer tout verre de protection fêlé.
 Este simbolo indica que hay que 'reemplazar filtros en caso de rotura o desperfectos'.
Dette symbolet indikerer at alle ødelagte (sprukne) sikkerhetsglass må skiftes.
 Valaisinta el saa käyttää ilman suojalasia vioittunut suojalasi on vaihdettava uuteen ennen valaisimen käyttöön ottoa.

< Millimetres >

This Electrical Product **MUST** be recycled.

01.08

