

NB This summary is a domestic guide only. For non-domestic situations or if you are in any doubt about positioning a light fitting, consult a qualified electrician.

Installed electrical equipment shall have at least the following degrees of protection:

In ZONE 0 : IPX7


In ZONE 1 and 2 : IPX4

Electrical equipment exposed to water jets, e.g. for cleaning purposes, shall have a degree of protection of at least IPX5


*** ZONE 1** if the space is accessible without the use of a tool.

Spaces under the bath accessible only with the use of a tool are **Outside ZONES**


A) Bath Tub.



B) Shower Basin.



A) Shower without Basin, but with a permanent fixed partition.



Replace any cracked protective shield.

Dieses symbol bedeutet, dass defekte schutzgläser sofort ersetzt werden müssen.

Ce symbole indique que vous devez remplacer tout verre de protection fêlé.

Este simbolo indica que hay que 'reemplazar filtros en caso de rotura o desperfectos'.

Dette symbolet indikerer at alle delagte (sprukne) sikkerhetglass må skiftes.

Valaisinta el saa käyttää ilman suojalasia vioitunut suojalasi on vaihdettava uuteen ennen valaisimen käyttöön ottoa.

Suitable for use indoors

Geeignet für Innenanwendung

Pour un usage interne

Adecuada para uso en interiores

Geschild voor gebruik binnen

Lämplig för inomhusbruk

