


# LED150 TC-T/-D Emergency

**F** This Product **MUST** be EARTHED










# IS720J

- 1 x 18W TC-DE 160Ø
- 2033881 2033883 2034033 2034035
- 2034073 2034075 2034113 2034115
- 1 x 26W TC-DE 160Ø
- 2033885 2033887 2034037 2034040
- 2034077 2034080 2034117 2034120
- 2 x 13W TC-DE 160Ø
- 2033890 2033892 2034042 2034044
- 2034082 2034084 2034122 2034124
- 1 x 32W TC-TE 185Ø
- 2033894 2033896 2034046 2034048
- 2034086 2034088 2034126 2034128
- 2 x 18W TC-TE 185Ø
- 2033898 2033901 2034051 2034053
- 2034091 2034093 2034131 2034133
- 2 x 26W TC-TE 185Ø
- 2033903 2033905 2034055 2034057
- 2034095 2034097 2034135 2034137
- 2 x 26W TC-TE or TC-DE/2 x 32W TC-TE 215Ø
- 2033907 2033910 2034060 2034062
- 2034100 2034102 2034140 2034142
- 1 x 42W TC-TE 215Ø
- 2033916 2033918 2034068 2034071
- 2034108 2034111 2034148 2034151
- \* 2 x 42W TC-TE 215Ø
- 2033912 2033914 2034064 2034066
- 2034104 2034106 2034144 2034146







**Disconnect from mains supply before replacing the fuse or the lamp.**  
**Vor dem Einsetzen der Sicherung oder der Lampe Spannungsfreiheit herstellen.**  
**Débrancher le secteur avant de remplacer le fusible ou l'ampoule.**  
**Desconectar del suministro de la red, antes de realizar la sustitución del fusible o de la lámpara.**  
**Voor het vervangen van lamp of zekering, eerst netspanning uitschakelen.**  
**Koppla bort spänningen före byte av en säkring eller en lampå.**



**Switch Off**  
**Abschalten**  
**Couper le conector**  
**Desconectar**  
**Uitschakelen**  
**Stäng av**




! A period of 24 Hours should be allowed after the mains supply has been switched on, to allow batteries to charge to full power



**DIM**

4x 1-10V



**IMPORTANT NOTE**

When using TC-T lamps, install in still air voids only!

**WICHTIGER HINWEIS**

Bei Verwendung von TC-T Lampen, auf genügende Durchlüftung achten!

**IMPORTANT**

Utiliser les lampes TC-T dans un environnement avec température stable

**IMPORTANTE**


Cuando utilice lámparas TC-T instatar sólo en espacios ventilados.

**LET OP**

Gebruik TC-T lampen slechts in TOCHTVRUJE ruimten.

**VIKTIG INFORMATION**

Bör ej användas vid installation i ventilerade undertak



**Routine Maintenance**

Routine maintenance must be carried out in compliance with the requirements of BS5266:Part 1 - Emergency Lighting of Premises.

The following tests assume a three-hour system.

- Daily:**
1. Check that any recorded faults have been rectified.
  2. Check that the maintained emergency lamp is operative.
  3. Check that the charge indicator light is illuminated.
- Monthly:**  
(Functional)
1. Simulate a mains failure and check that the emergency lamp illuminates and remains on for several minutes.
  2. After reverting back to mains supply check the charge indicator light is illuminated.
- Six Monthly:**  
(1 Hour)
1. Simulate a mains failure and check that the emergency lamp illuminates and remains on for one hour.
  2. After reverting back to mains supply check the charge indicator light is illuminated.
  3. On restoring the mains supply the unit will require approximately 24 hours to recharge before becoming fully operational.
- Three Years:**  
(3 Hours)
1. Simulate a mains failure and check that the emergency lamp illuminates and remains on for at least 3 hours.
  2. After reverting back to mains supply check the charge indicator light is illuminated.
  3. On restoring the mains supply the unit will require approximately 24 hours to recharge before becoming fully operational.

It is recommended that the battery packs and lamps are replaced every 4 years or sooner if the units performance fails to meet the above requirements. To maintain optimum unit performance, only approved replacement battery packs and lamps must be used.

All routine maintenance checks must be recorded on the unit Routine Test Record and must be made available for inspection at all times.

**Installation and Commissioning Record**

Luminaire Model Ref: \_\_\_\_\_ Location: \_\_\_\_\_

Installed By: \_\_\_\_\_ Date: \_\_\_\_\_

Commissioned by: \_\_\_\_\_ Date: \_\_\_\_\_

(Full Charge and Discharge Cycle)

**Routine Test Record**

Monthly Test	First Year		Second Year		Third Year		Forth Year		Fifth Year	
	Signed	Dated	Signed	Dated	Signed	Dated	Signed	Dated	Signed	Dated
Functional										
Functional										
Functional										
Functional										
Functional										
1 Hour Duration										
Functional										
Functional										
Functional										
Functional										
Functional										
1 Hour Duration										
3 Hour Duration										

**Replace any cracked protective shield.**  
 Dieses symbol bedeutet, dass defekte schutzgläser sofort ersetzt werden müssen.  
**Ce symbole indique que vous devez remplacer tout verre de protection fêlé.**  
 Este simbolo indica que hay que 'reemplazar filtros en caso de rotura o desperfectos'.  
**Dette symbolet indikerer at alle ødelagte (sprukne) sikkerhetsglass må skiftes.**  
 Valaisinta el saa käyttää ilman suojalasia vioittunut suojalasi on vaihdettava uuteen ennen valaisimen käyttöön ottoa.

< Millimetres >



**Concord**

Avis Way Newhaven East Sussex BN9 0ED  
 T 0870 606 2030 F 01273 512 688 email: information@concordmarlin.com

